



NOTE:

1. SIDEWALK TO HAVE STIFF BROOM FINISH WITH TROWELED EDGES.
2. PROVIDE 1/2" EXPANSION JOINT AT NEW SIDEWALK ABUTTING EXISTING SIDEWALK.
3. THE CONCRETE APRON SHALL BE 6" THICK CONCRETE ON A 4" COMPACTED STONE BASE, 4000 PSI CONCRETE WITH 10X10X10 MESH IN APRON AND SIDEWALK.
4. SIDEWALK MAY BE LOWERED IN VICINITY OF APRON SO THAT AN ORDERLY TRANSITION IS POSSIBLE.
5. THE DRIVEWAY SHALL NOT EXCEED 10%
6. THE DEPRESSED SIDEWALK IS NOT TO EXCEED 1/4" PER FOOT LONGITUDINALLY.

Center Township Standard Detail

CONCRETE DRIVEWAY / SIDEWALK APRON

SD20